

Certificate



Certificate no.

CU 72080149 01

License Holder:

American Power Conversion
Holding Inc.
4F No. 205, Sec. 3, Beishin Rd.
223, Shindian City, Taipei
Taiwan - R.O.C.

Manufacturing Plant:

International Precision
Assembly Inc.
Lot 6 Blk 8, Phase II Peza
4000 Rosario Cavite
Philippines

Test report no.: USA-DS 30880162 001

Client Reference: Eric Fan

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply

License Fee - Units

Model Designation: 1) BE350Gxxxxxxxxxx
2) BE450Gxxxxxxxxxx
3) BE550Gxxxxxxxxxx

7

... 0/8, =, 0-9, A-Z, *, #, space, blank)

Rated Voltage: AC 120V, 60Hz

Rated Current: 1) 8A

2), 3) 12A

Protection Class: I

cont'd

7

Appendix: 1, 1-10^

Test mark:

Signatures

Date of Issue
(day/mo/yr)

30/01/2008



Stephan Schmitt
President

Dipl.-Ing. R. Behrends
QA Certification Officer

Certificate



Certificate no.

CU 72080149 02

License Holder:

American Power Conversion
Holding Inc.
4F No. 205, Sec. 3, Beishin Rd.
231 Shindian City, Taipei
Taiwan - ROC

Manufacturing Plant:

International Precision
Assemblies, Inc. Plant 2
Lot 2 Blk 17, Phase IV Peza
4106 Rosario Cavite
Philippines

Test report no.: USA-DS 30880162 001

Client Reference: Eric Fan

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply

License Fee - Units

contd.

Output Ratings:

- 1) UPS Output: AC 120V, 60Hz; 2.9A; 200W; 350VA
Surge Output: AC 120V, 60Hz; Total Output Current: 8A
- 2) UPS Output: AC 120V, 60Hz; 3.7A; 257W; 450VA
Surge Output: AC 120V, 60Hz; Total Output Current: 12A
- 3) UPS Output: AC 120V, 60Hz; 4.6A; 330W; 550VA
Surge Output: AC 120V, 60Hz; Total Output Current: 12A

Additional Manufacturing Plant: see above (K752456)

Licensed Test mark:



Signatures

Date of Issue
(day/mo/yr)
30/01/2008

Stephan Schmitt
Stephan Schmitt
President

R. Behrends
Dipl.-Ing. R. Behrends
QA Certification Officer

Certificate



Certificate no.

CU 72080149 03

License Holder:

American Power Conversion
Holding Inc.
4F No. 205, Sec. 3, Beishin Rd.
231 Shindian City, Taipei
Taiwan - R.O.C.

Manufacturing Plant:

Danam Philippines Inc.
Lot 1-A, Block 15, Phase III, PEZA
4106 Rosario, Cavite
Philippines

Test report no.: USA-DS 30880162 001

Client Reference: Eric Fan

Tested to: UL 1778:2005 R7.06
C22.2 No. 107.3-05 + A1:06

Certified Product: Uninterruptible Power Supply

License Fee - Units

Additional Manufacturing Plants: see above

(VRF2545)

Licensed Test mark:



Signatures

S. Schmitt *R. Behrends*

Stephan Schmitt
President

Dipl.-Ing. R. Behrends
QA Certification Officer

Date of Issue
(day/mo/yr)

30/01/2008